

3-cycle Deficiencies - Software provided by the Coalition for Quality Care - Reports Compiled by Voices for Quality Care Valid 7/15

provnum	Provname	address	state	zip	survey date output	Survey Type	defpr ef	tag	tag desc	scope	defstat	statdate	cycle	stand ard	complai nt
Homes: 5		DC													
Sets: 1	CAPITOL HILL NURSING AND REHABILITATION CENTER	DC													
95027	CAPITOL HILL NURSING AND REHABILITATION CENTER	700 CONSTITUTION AVE. NE	DC	20002	8/11/14	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	9/15/14	1	Y	N
95027	CAPITOL HILL NURSING AND REHABILITATION CENTER	700 CONSTITUTION AVE. NE	DC	20002	7/30/13	Fire Safety	K	18	Corridor and hallway doors that block smoke.	C	Deficient, Provider has date of correction	10/7/13	2	Y	N
95027	CAPITOL HILL NURSING AND REHABILITATION CENTER	700 CONSTITUTION AVE. NE	DC	20002	9/6/12	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	10/11/12	3	Y	N
Sets: 1	CARROLL MANOR NURSING & REHAB	DC													
95034	CARROLL MANOR NURSING & REHAB	725 BUCHANAN ST., NE	DC	20017	10/7/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	11/13/14	1	Y	N
95034	CARROLL MANOR NURSING & REHAB	725 BUCHANAN ST., NE	DC	20017	9/26/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	10/16/13	2	Y	N
95034	CARROLL MANOR NURSING & REHAB	725 BUCHANAN ST., NE	DC	20017	9/21/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	11/16/12	3	Y	N
Sets: 2	DEANWOOD REHABILITATION AND WELLNESS CENTER	DC													
95019	DEANWOOD REHABILITATION AND WELLNESS CENTER	5000 BURROUGHS AVE. NE	DC	20019	2/25/14	Fire Safety	K	18	Corridor and hallway doors that block smoke.	E	Deficient, Provider has date of correction	5/2/14	1	Y	N
95019	DEANWOOD REHABILITATION AND WELLNESS CENTER	5000 BURROUGHS AVE. NE	DC	20019	3/27/13	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	5/9/13	2	Y	N

95019	DEANWOOD REHABILITATION AND WELLNESS CENTER	5000 BURROUGHS AVE. NE	DC	20019	3/29/12	Fire Safety	K	18	Corridor and hallway doors that block smoke.	E	Deficient, Provider has date of correction	7/6/12	3	Y	N
95019	DEANWOOD REHABILITATION AND WELLNESS CENTER	5000 BURROUGHS AVE. NE	DC	20019	2/25/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	5/2/14	1	Y	N
95019	DEANWOOD REHABILITATION AND WELLNESS CENTER	5000 BURROUGHS AVE. NE	DC	20019	3/27/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	5/9/13	2	Y	N
95019	DEANWOOD REHABILITATION AND WELLNESS CENTER	5000 BURROUGHS AVE. NE	DC	20019	3/29/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	7/6/12	3	Y	N
Sets: 1	INGLESIDE AT ROCK CREEK	DC													
95028	INGLESIDE AT ROCK CREEK	3050 MILITARY ROAD NW	DC	20015	9/8/14	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	10/21/14	1	Y	N
95028	INGLESIDE AT ROCK CREEK	3050 MILITARY ROAD NW	DC	20015	6/20/13	Fire Safety	K	18	Corridor and hallway doors that block smoke.	E	Deficient, Provider has date of correction	8/9/13	2	Y	N
95028	INGLESIDE AT ROCK CREEK	3050 MILITARY ROAD NW	DC	20015	8/21/12	Fire Safety	K	18	Corridor and hallway doors that block smoke.	E	Deficient, Provider has date of correction	10/18/12	3	Y	N
Sets: 1	TRANSITIONS HEALTHCARE CAPITOL CITY	DC													
95022	TRANSITIONS HEALTHCARE CAPITOL CITY	2425 25TH STREET SE	DC	20020	12/1/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	1/20/15	1	Y	N
95022	TRANSITIONS HEALTHCARE CAPITOL CITY	2425 25TH STREET SE	DC	20020	11/5/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	2/11/14	2	Y	N
95022	TRANSITIONS HEALTHCARE CAPITOL CITY	2425 25TH STREET SE	DC	20020	10/24/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	11/30/12	3	Y	N