

215126	BERLIN NURSING AND REHABILITATION CENTER	9715 HEALTHWAY DRIVE, PO BOX 799	BERLIN	MD	21811	2/14/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	B	Deficient, Provider has date of correction	2/19/14	1	Y	N
215126	BERLIN NURSING AND REHABILITATION CENTER	9715 HEALTHWAY DRIVE, PO BOX 799	BERLIN	MD	21811	1/7/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	E	Deficient, Provider has date of correction	2/15/13	2	Y	N
215126	BERLIN NURSING AND REHABILITATION CENTER	9715 HEALTHWAY DRIVE, PO BOX 799	BERLIN	MD	21811	11/7/11	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	11/7/11	3	Y	N
Sets: 1	BRADFORD OAKS CENTER	MD														
215165	BRADFORD OAKS CENTER	7520 SURRETTTS ROAD	CLINTON	MD	20735	10/10/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	F	Deficient, Provider has date of correction	11/20/14	1	Y	N
215165	BRADFORD OAKS CENTER	7520 SURRETTTS ROAD	CLINTON	MD	20735	8/26/13	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	F	Deficient, Provider has date of correction	10/22/13	2	Y	N
215165	BRADFORD OAKS CENTER	7520 SURRETTTS ROAD	CLINTON	MD	20735	7/10/12	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	F	Deficient, Provider has date of correction	8/10/12	3	Y	N
Sets: 1	BRINTON WOODS POST ACUTE CARE CENTER	MD														
215330	BRINTON WOODS POST ACUTE CARE CENTER	5009 FRANKFORD AVENUE	BALTIMORE	MD	21206	9/5/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	10/30/14	1	Y	N
215330	BRINTON WOODS POST ACUTE CARE CENTER	5009 FRANKFORD AVENUE	BALTIMORE	MD	21206	12/5/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	2/12/14	2	Y	N

215231	CLINTON NURSING & REHABILITATION CENTER	9211 STUART LANE	CLINTON	MD	20735	7/22/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	8/21/14	1	Y	N
215231	CLINTON NURSING & REHABILITATION CENTER	9211 STUART LANE	CLINTON	MD	20735	3/1/13	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	3/20/13	2	Y	N
215231	CLINTON NURSING & REHABILITATION CENTER	9211 STUART LANE	CLINTON	MD	20735	2/14/12	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	3/5/12	3	Y	N
Sets: 1	COLLINGSWOOD NSG. & REHAB.	MD														
215092	COLLINGSWOOD NSG. & REHAB. CEN	299 HURLEY AVENUE	ROCKVILLE	MD	20850	3/14/14	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	D	Deficient, Provider has date of correction	3/25/14	1	Y	N
215092	COLLINGSWOOD NSG. & REHAB. CEN	299 HURLEY AVENUE	ROCKVILLE	MD	20850	2/13/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	B	Deficient, Provider has date of correction	2/28/13	2	Y	N
215092	COLLINGSWOOD NSG. & REHAB. CEN	299 HURLEY AVENUE	ROCKVILLE	MD	20850	4/12/12	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	C	Deficient, Provider has date of correction	5/31/12	3	Y	N
Sets: 2	CRAWFORD RETREAT	MD														
#####	CRAWFORD RETREAT	2117 DENISON STREET	BALTIMORE	MD	21216	7/24/14	Fire Safety	K	12	Approved construction type or materials.	F	Deficient, Provider has date of correction	9/10/14	1	Y	N
#####	CRAWFORD RETREAT	2117 DENISON STREET	BALTIMORE	MD	21216	4/23/13	Fire Safety	K	12	Approved construction type or materials.	C	Deficient, Provider has date of correction	5/2/13	2	Y	N
#####	CRAWFORD RETREAT	2117 DENISON STREET	BALTIMORE	MD	21216	6/4/12	Fire Safety	K	12	Approved construction type or materials.	C	Deficient, Provider has date of correction	6/30/12	3	Y	N
#####	CRAWFORD RETREAT	2117 DENISON STREET	BALTIMORE	MD	21216	7/24/14	Fire Safety	K	39	Corridors or aisles that are unobstructed and are at least 8 feet in width.	E	Deficient, Provider has date of correction	9/10/14	1	Y	N

#####	CRAWFORD RETREAT	2117 DENISON STREET	BALTIMORE	MD	21216	4/23/13	Fire Safety	K	39	Corridors or aisles that are unobstructed and are at least 8 feet in width.	C	Deficient, Provider has date of correction	5/2/13	2	Y	N
#####	CRAWFORD RETREAT	2117 DENISON STREET	BALTIMORE	MD	21216	6/4/12	Fire Safety	K	39	Corridors or aisles that are unobstructed and are at least 8 feet in width.	C	Deficient, Provider has date of correction	6/30/12	3	Y	N
Sets: 1	CRESCENT CITIES CENTER	MD														
215323	CRESCENT CITIES CENTER	4409 EAST WEST HIGHWAY	RIVERDALE	MD	20737	8/19/14	Fire Safety	K	25	Walls that prevent smoke from passing through and would resist fire for at least one hour.	D	Deficient, Provider has date of correction	11/13/14	1	Y	N
215323	CRESCENT CITIES CENTER	4409 EAST WEST HIGHWAY	RIVERDALE	MD	20737	5/22/13	Fire Safety	K	25	Walls that prevent smoke from passing through and would resist fire for at least one hour.	D	Deficient, Provider has date of correction	6/30/13	2	Y	N
215323	CRESCENT CITIES CENTER	4409 EAST WEST HIGHWAY	RIVERDALE	MD	20737	4/10/12	Fire Safety	K	25	Walls that prevent smoke from passing through and would resist fire for at least one hour.	F	Deficient, Provider has date of correction	5/22/12	3	Y	N
Sets: 1	CROFTON CONVALESCENT CENTER	MD														
215120	CROFTON CONVALESCENT CENTER	2131 DAVIDSONVILL E ROAD	CROFTON	MD	21114	3/4/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has no plan of correction		1	Y	N
215120	CROFTON CONVALESCENT CENTER	2131 DAVIDSONVILL E ROAD	CROFTON	MD	21114	2/5/13	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	2/19/13	2	Y	N
215120	CROFTON CONVALESCENT CENTER	2131 DAVIDSONVILL E ROAD	CROFTON	MD	21114	11/15/11	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	11/16/11	3	Y	N
Sets: 1	CROMWELL	MD														
215129	CROMWELL CENTER	8710 EMGE ROAD	BALTIMORE	MD	21234	3/6/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	3/18/14	1	Y	N

215129	CROMWELL CENTER	8710 EMGE ROAD	BALTIMORE	MD	21234	11/27/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	1/25/13	2	Y	N
215129	CROMWELL CENTER	8710 EMGE ROAD	BALTIMORE	MD	21234	9/8/11	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	9/9/11	3	Y	N
Sets: 1	EGLE NURSING HOME	MD														
215307	EGLE NURSING HOME	57 JACKSON STREET	LONACONING	MD	21539	8/6/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	9/5/14	1	Y	N
215307	EGLE NURSING HOME	57 JACKSON STREET	LONACONING	MD	21539	5/29/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	5/29/13	2	Y	N
215307	EGLE NURSING HOME	57 JACKSON STREET	LONACONING	MD	21539	4/11/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	5/23/12	3	Y	N
Sets: 1	ELKTON CENTER	MD														
215269	ELKTON CENTER	ONE PRICE DRIVE	ELKTON	MD	21921	1/19/15	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	3/19/15	1	Y	N
215269	ELKTON CENTER	ONE PRICE DRIVE	ELKTON	MD	21921	12/26/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	1/26/14	2	Y	N
215269	ELKTON CENTER	ONE PRICE DRIVE	ELKTON	MD	21921	4/22/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	5/30/13	3	Y	N
Sets: 1	FAIRFIELD NURSING & REHABILITATION CENTER	MD														
215236	FAIRFIELD NURSING & REHABILITATION CENTER	1454 FAIRFIELD LOOP ROAD	CROWNSVILLE	MD	21032	10/2/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	B	Deficient, Provider has date of correction	12/31/14	1	Y	N

215236	FAIRFIELD NURSING & REHABILITATION CENTER	1454 FAIRFIELD LOOP ROAD	CROWNSVILLE	MD	21032	10/2/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	B	Deficient, Provider has date of correction	12/13/13	2	Y	N
215236	FAIRFIELD NURSING & REHABILITATION CENTER	1454 FAIRFIELD LOOP ROAD	CROWNSVILLE	MD	21032	8/27/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	9/21/12	3	Y	N
Sets: 1	FAIRLAND	MD														
215015	FAIRLAND CENTER	2101 FAIRLAND ROAD	SILVER SPRING	MD	20904	9/9/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	10/10/14	1	Y	N
215015	FAIRLAND CENTER	2101 FAIRLAND ROAD	SILVER SPRING	MD	20904	9/11/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	10/25/13	2	Y	N
215015	FAIRLAND CENTER	2101 FAIRLAND ROAD	SILVER SPRING	MD	20904	9/7/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	E	Deficient, Provider has date of correction	10/22/12	3	Y	N
Sets: 1	FORT WASHINGTON HEALTH & REHABILITATION	MD														
215146	FORT WASHINGTON HEALTH & REHABILITATION	12021 LIVINGSTON ROAD	FORT WASHINGTON	MD	20744	4/22/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	5/23/14	1	Y	N
215146	FORT WASHINGTON HEALTH & REHABILITATION	12021 LIVINGSTON ROAD	FORT WASHINGTON	MD	20744	4/23/13	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	F	Deficient, Provider has date of correction	6/1/13	2	Y	N

215146	FORT WASHINGTON HEALTH & REHABILITATION	12021 LIVINGSTON ROAD	FORT WASHINGTON	MD	20744	4/12/12	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	7/1/12	3	Y	N
Sets: 3	FOX CHASE REHAB & NURSING CENTER	MD														
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/15/15	Fire Safety	K	18	Corridor and hallway doors that block smoke.	C	Deficient, Provider has date of correction	3/30/15	1	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/16/14	Fire Safety	K	18	Corridor and hallway doors that block smoke.	B	Deficient, Provider has date of correction	3/12/14	2	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/15/13	Fire Safety	K	18	Corridor and hallway doors that block smoke.	B	Deficient, Provider has date of correction	2/28/13	3	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/15/15	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	E	Deficient, Provider has date of correction	3/30/15	1	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/16/14	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	C	Deficient, Provider has date of correction	3/12/14	2	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/15/13	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	E	Deficient, Provider has date of correction	2/28/13	3	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/15/15	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	3/30/15	1	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/16/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	3/12/14	2	Y	N
215197	FOX CHASE REHAB & NURSING CENTER	2015 EAST-WEST HIGHWAY	SILVER SPRING	MD	20910	1/15/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	2/28/13	3	Y	N
Sets: 1	FUTURE CARE CHARLES VILLAGE, LLC	MD														
215324	FUTURE CARE CHARLES VILLAGE, LLC	2327 N. CHARLES ST	BALTIMORE	MD	21218	9/18/14	Fire Safety	K	71	Properly constructed linen or trash chutes.	E	Deficient, Provider has date of correction	12/2/14	1	Y	N

215324	FUTURE CARE CHARLES VILLAGE, LLC	2327 N. CHARLES ST	BALTIMORE	MD	21218	11/7/13	Fire Safety	K	71	Properly constructed linen or trash chutes.	E	Deficient, Provider has date of correction	1/10/14	2	Y	N
215324	FUTURE CARE CHARLES VILLAGE, LLC	2327 N. CHARLES ST	BALTIMORE	MD	21218	7/17/12	Fire Safety	K	71	Properly constructed linen or trash chutes.	F	Deficient, Provider has date of correction	8/17/12	3	Y	N
Sets: 2	FUTURE CARE HOMEWOOD	MD														
215249	FUTURE CARE HOMEWOOD	2700 N. CHARLES ST.	BALTIMORE	MD	21218	6/12/14	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	F	Deficient, Provider has date of correction	8/18/14	1	Y	N
215249	FUTURE CARE HOMEWOOD	2700 N. CHARLES ST.	BALTIMORE	MD	21218	7/15/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	E	Deficient, Provider has date of correction	8/9/13	2	Y	N
215249	FUTURE CARE HOMEWOOD	2700 N. CHARLES ST.	BALTIMORE	MD	21218	4/4/12	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	E	Deficient, Provider has date of correction	4/30/12	3	Y	N
215249	FUTURE CARE HOMEWOOD	2700 N. CHARLES ST.	BALTIMORE	MD	21218	6/12/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	8/18/14	1	Y	N
215249	FUTURE CARE HOMEWOOD	2700 N. CHARLES ST.	BALTIMORE	MD	21218	7/15/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	8/9/13	2	Y	N
215249	FUTURE CARE HOMEWOOD	2700 N. CHARLES ST.	BALTIMORE	MD	21218	4/4/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	4/30/12	3	Y	N
Sets: 2	FUTURE CARE IRVINGTON	MD														
215219	FUTURE CARE IRVINGTON	22 SOUTH ATHOL AVENUE	BALTIMORE	MD	21229	6/30/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	9/1/14	1	Y	N

215219	FUTURE CARE IRVINGTON	22 SOUTH ATHOL AVENUE	BALTIMORE	MD	21229	4/15/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	E	Deficient, Provider has date of correction	6/10/13	2	Y	N
215219	FUTURE CARE IRVINGTON	22 SOUTH ATHOL AVENUE	BALTIMORE	MD	21229	4/11/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	B	Deficient, Provider has date of correction	5/30/12	3	Y	N
215219	FUTURE CARE IRVINGTON	22 SOUTH ATHOL AVENUE	BALTIMORE	MD	21229	6/30/14	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	D	Deficient, Provider has date of correction	9/1/14	1	Y	N
215219	FUTURE CARE IRVINGTON	22 SOUTH ATHOL AVENUE	BALTIMORE	MD	21229	4/15/13	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	C	Deficient, Provider has date of correction	6/10/13	2	Y	N
215219	FUTURE CARE IRVINGTON	22 SOUTH ATHOL AVENUE	BALTIMORE	MD	21229	4/11/12	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	C	Deficient, Provider has date of correction	5/30/12	3	Y	N
Sets: 1	FUTURE CARE OLD COURT	MD														
215118	FUTURE CARE OLD COURT	5412 OLD COURT ROAD	RANDALLST OWN	MD	21133	3/17/15	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	F	Deficient, Provider has date of correction	4/30/15	1	N	Y
215118	FUTURE CARE OLD COURT	5412 OLD COURT ROAD	RANDALLST OWN	MD	21133	10/1/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	C	Deficient, Provider has date of correction	11/14/13	2	Y	N
215118	FUTURE CARE OLD COURT	5412 OLD COURT ROAD	RANDALLST OWN	MD	21133	10/23/12	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	E	Deficient, Provider has date of correction	12/31/12	3	Y	N
Sets: 1	GLADE VALLEY CENTER	MD														
215313	GLADE VALLEY CENTER	56 WEST FREDERICK STREET	WALKERSVI LLE	MD	21793	4/23/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	F	Deficient, Provider has date of correction	6/19/14	1	Y	N

215313	GLADE VALLEY CENTER	56 WEST FREDERICK STREET	WALKERSVILLE	MD	21793	2/25/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	2/25/13	2	Y	N
215313	GLADE VALLEY CENTER	56 WEST FREDERICK STREET	WALKERSVILLE	MD	21793	1/3/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	2/3/12	3	Y	N
Sets: 1	GOLDEN LIVINGCENTER-WESTMINSTER	MD														
215094	GOLDEN LIVINGCENTER-WESTMINSTER	1234 WASHINGTON BOULEVARD	WESTMINSTER	MD	21157	12/3/14	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	12/19/14	1	Y	N
215094	GOLDEN LIVINGCENTER-WESTMINSTER	1234 WASHINGTON BOULEVARD	WESTMINSTER	MD	21157	9/27/13	Fire Safety	K	18	Corridor and hallway doors that block smoke.	C	Deficient, Provider has date of correction	10/25/13	2	Y	N
215094	GOLDEN LIVINGCENTER-WESTMINSTER	1234 WASHINGTON BOULEVARD	WESTMINSTER	MD	21157	8/1/12	Fire Safety	K	18	Corridor and hallway doors that block smoke.	C	Deficient, Provider has date of correction	10/16/12	3	Y	N
Sets: 1	GOOD SAMARITAN	MD														
215241	GOOD SAMARITAN NURSING CENTER	1601 E. BELVEDERE AVENUE	BALTIMORE	MD	21239	10/16/14	Fire Safety	K	71	Properly constructed linen or trash chutes.	E	Deficient, Provider has date of correction	1/1/15	1	Y	N
215241	GOOD SAMARITAN NURSING CENTER	1601 E. BELVEDERE AVENUE	BALTIMORE	MD	21239	10/1/13	Fire Safety	K	71	Properly constructed linen or trash chutes.	D	Deficient, Provider has date of correction	11/14/13	2	Y	N
215241	GOOD SAMARITAN NURSING CENTER	1601 E. BELVEDERE AVENUE	BALTIMORE	MD	21239	12/19/12	Fire Safety	K	71	Properly constructed linen or trash chutes.	E	Deficient, Provider has date of correction	3/18/13	3	Y	N
Sets: 1	HEBREW HOME OF GREATER WASHINGTON	MD														
215071	HEBREW HOME OF GREATER WASHINGTON	6121 MONTROSE ROAD	ROCKVILLE	MD	20852	10/28/14	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	C	Deficient, Provider has date of correction	10/31/14	1	Y	N

215071	HEBREW HOME OF GREATER WASHINGTON	6121 MONTROSE ROAD	ROCKVILLE	MD	20852	10/25/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	C	Deficient, Provider has date of correction	11/17/13	2	Y	N
215071	HEBREW HOME OF GREATER WASHINGTON	6121 MONTROSE ROAD	ROCKVILLE	MD	20852	11/2/12	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	B	Deficient, Provider has date of correction	11/7/12	3	Y	N
Sets: 4	HOLLY HILL NURSING AND REHABILITATION CENTER	MD														
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/29/14	Fire Safety	K	12	Approved construction type or materials.	E	Deficient, Provider has date of correction	8/27/14	1	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/23/13	Fire Safety	K	12	Approved construction type or materials.	E	Deficient, Provider has date of correction	8/7/13	2	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	6/12/12	Fire Safety	K	12	Approved construction type or materials.	E	Deficient, Provider has date of correction	7/13/12	3	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/29/14	Fire Safety	K	20	Proper stairway enclosures and vertical shafts.	E	Deficient, Provider has date of correction	8/27/14	1	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/23/13	Fire Safety	K	20	Proper stairway enclosures and vertical shafts.	E	Deficient, Provider has date of correction	8/7/13	2	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	6/12/12	Fire Safety	K	20	Proper stairway enclosures and vertical shafts.	E	Deficient, Provider has date of correction	7/13/12	3	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/29/14	Fire Safety	K	33	Protected exits that allow the resident to escape the building.	E	Deficient, Provider has date of correction	8/27/14	1	Y	N

215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/23/13	Fire Safety	K	33	Protected exits that allow the resident to escape the building.	E	Deficient, Provider has date of correction	8/7/13	2	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	6/12/12	Fire Safety	K	33	Protected exits that allow the resident to escape the building.	E	Deficient, Provider has date of correction	7/13/12	3	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/29/14	Fire Safety	K	34	Exit stairways and towers that are smoke proof.	E	Deficient, Provider has date of correction	8/27/14	1	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	7/23/13	Fire Safety	K	34	Exit stairways and towers that are smoke proof.	E	Deficient, Provider has date of correction	8/7/13	2	Y	N
215204	HOLLY HILL NURSING AND REHABILITATION CENTER	531 STEVENSON LANE	TOWSON	MD	21286	6/12/12	Fire Safety	K	34	Exit stairways and towers that are smoke proof.	E	Deficient, Provider has date of correction	7/13/12	3	Y	N
Sets: 1	HOMEWOOD CENTER	MD														
215074	HOMEWOOD CENTER	6000 BELLONA AVENUE	BALTIMORE	MD	21212	5/1/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	5/22/14	1	Y	N
215074	HOMEWOOD CENTER	6000 BELLONA AVENUE	BALTIMORE	MD	21212	3/5/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	4/30/13	2	Y	N
215074	HOMEWOOD CENTER	6000 BELLONA AVENUE	BALTIMORE	MD	21212	12/15/11	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	2/13/12	3	Y	N
Sets: 1	KENSINGTON NURSING & REHABILITATION CENTER	MD														
215043	KENSINGTON NURSING & REHABILITATION CENTER	3000 MCCOMAS AVENUE	KENSINGTON	MD	20895	4/1/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	4/15/14	1	Y	N

215017	LONGVIEW NSG. HOME	3332 MAIN STREET	MANCHESTER	MD	21102	4/30/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	5/22/14	1	Y	N
215017	LONGVIEW NSG. HOME	3332 MAIN STREET	MANCHESTER	MD	21102	4/2/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	5/30/13	2	Y	N
215017	LONGVIEW NSG. HOME	3332 MAIN STREET	MANCHESTER	MD	21102	1/26/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	4/1/12	3	Y	N
Sets: 1	LORIEN HEALTH SYSTEMS - COLUMBIA	MD														
215112	LORIEN HEALTH SYSTEMS - COLUMBIA	6334 CEDAR LANE	COLUMBIA	MD	21044	10/3/14	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	11/30/14	1	Y	N
215112	LORIEN HEALTH SYSTEMS - COLUMBIA	6334 CEDAR LANE	COLUMBIA	MD	21044	10/23/13	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	12/5/13	2	Y	N
215112	LORIEN HEALTH SYSTEMS - COLUMBIA	6334 CEDAR LANE	COLUMBIA	MD	21044	8/15/12	Fire Safety	K	18	Corridor and hallway doors that block smoke.	D	Deficient, Provider has date of correction	10/30/12	3	Y	N
Sets: 1	LORIEN HEALTH SYSTEMS MT	MD														
215335	LORIEN HEALTH SYSTEMS MT AIRY	705 MIDWAY AVENUE	MOUNT AIRY	MD	21771	7/9/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	7/30/14	1	Y	N
215335	LORIEN HEALTH SYSTEMS MT AIRY	705 MIDWAY AVENUE	MOUNT AIRY	MD	21771	5/17/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	6/17/13	2	Y	N
215335	LORIEN HEALTH SYSTEMS MT AIRY	705 MIDWAY AVENUE	MOUNT AIRY	MD	21771	3/20/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	4/20/12	3	Y	N
Sets: 1	LORIEN NURSING & REHAB CTR - ELKRIDGE	MD														
215357	LORIEN NURSING & REHAB CTR - ELKRIDGE	7615 WASHINGTON BOULEVARD	ELKRIDGE	MD	21075	7/25/14	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	B	Deficient, Provider has date of correction	9/1/14	1	Y	N

215357	LORIEN NURSING & REHAB CTR - ELKRIDGE	7615 WASHINGTON BOULEVARD	ELKRIDGE	MD	21075	7/23/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	D	Deficient, Provider has date of correction	9/15/13	2	Y	N
215357	LORIEN NURSING & REHAB CTR - ELKRIDGE	7615 WASHINGTON BOULEVARD	ELKRIDGE	MD	21075	6/27/12	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	C	Deficient, Provider has no plan of correction		3	Y	N
Sets: 1	MAGNOLIA	MD														
215108	MAGNOLIA CENTER	8200 GOOD LUCK ROAD	LANHAM	MD	20706	3/26/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	4/30/14	1	Y	N
215108	MAGNOLIA CENTER	8200 GOOD LUCK ROAD	LANHAM	MD	20706	4/10/13	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	6/22/13	2	Y	N
215108	MAGNOLIA CENTER	8200 GOOD LUCK ROAD	LANHAM	MD	20706	3/2/12	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	4/16/12	3	Y	N
Sets: 2	MANORCARE HEALTH SERVICES -	MD														
215077	MANORCARE HEALTH SERVICES -	7001 CHARLES STREET	TOWSON	MD	21204	12/11/14	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	E	Deficient, Provider has date of correction	2/2/15	1	Y	N
215077	MANORCARE HEALTH SERVICES -	7001 CHARLES STREET	TOWSON	MD	21204	10/18/13	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	D	Deficient, Provider has date of correction	11/5/13	2	Y	N
215077	MANORCARE HEALTH SERVICES -	7001 CHARLES STREET	TOWSON	MD	21204	1/21/13	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	D	Deficient, Provider has date of correction	2/28/13	3	Y	N
215077	MANORCARE HEALTH SERVICES -	7001 CHARLES STREET	TOWSON	MD	21204	12/11/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	F	Deficient, Provider has date of correction	2/2/15	1	Y	N
215077	MANORCARE HEALTH SERVICES -	7001 CHARLES STREET	TOWSON	MD	21204	10/18/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	11/5/13	2	Y	N

215077	MANORCARE HEALTH SERVICES -	7001 CHARLES STREET	TOWSON	MD	21204	1/21/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	4/24/13	3	Y	N
Sets: 1	MILFORD MANOR NURSING	MD														
215022	MILFORD MANOR NURSING HOME	4204 OLD MILFORD MILL ROAD	BALTIMORE	MD	21208	3/19/15	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	5/26/15	1	Y	N
215022	MILFORD MANOR NURSING HOME	4204 OLD MILFORD MILL ROAD	BALTIMORE	MD	21208	2/11/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	4/24/14	2	Y	N
215022	MILFORD MANOR NURSING HOME	4204 OLD MILFORD MILL ROAD	BALTIMORE	MD	21208	12/3/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	B	Deficient, Provider has date of correction	12/3/12	3	Y	N
Sets: 1	MULTI-MEDICAL CENTER	MD														
215096	MULTI-MEDICAL CENTER	7700 YORK ROAD	TOWSON	MD	21204	1/23/15	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	E	Deficient, Provider has date of correction	3/17/15	1	Y	N
215096	MULTI-MEDICAL CENTER	7700 YORK ROAD	TOWSON	MD	21204	9/30/13	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	F	Deficient, Provider has date of correction	10/30/13	2	Y	N
215096	MULTI-MEDICAL CENTER	7700 YORK ROAD	TOWSON	MD	21204	7/17/12	Fire Safety	K	72	Exits that are free from obstructions and can be used at all times.	E	Deficient, Provider has date of correction	10/12/12	3	Y	N
Sets: 1	NORTHAMPTON MANOR	MD														
215217	NORTHAMPTON MANOR	200 EAST 16TH STREET	FREDERICK	MD	21701	1/8/15	Fire Safety	K	25	Walls that prevent smoke from passing through and would resist fire for at least one hour.	E	Deficient, Provider has date of correction	2/20/15	1	Y	N
215217	NORTHAMPTON MANOR	200 EAST 16TH STREET	FREDERICK	MD	21701	10/8/13	Fire Safety	K	25	Walls that prevent smoke from passing through and would resist fire for at least one hour.	D	Deficient, Provider has date of correction	11/27/13	2	Y	N
215217	NORTHAMPTON MANOR	200 EAST 16TH STREET	FREDERICK	MD	21701	8/8/12	Fire Safety	K	25	Walls that prevent smoke from passing through and would resist fire for at least one hour.	C	Deficient, Provider has date of correction	9/24/12	3	Y	N

215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	9/22/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	12/11/14	1	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	8/21/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	F	Deficient, Provider has date of correction	11/5/13	2	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	5/14/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	E	Deficient, Provider has date of correction	8/4/12	3	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	9/22/14	Fire Safety	K	66	Posted "No-smoking" signs in areas where smoking is not permitted or ashtrays provided where smoking was allowed.	D	Deficient, Provider has date of correction	12/11/14	1	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	8/21/13	Fire Safety	K	66	Posted "No-smoking" signs in areas where smoking is not permitted or ashtrays provided where smoking was allowed.	D	Deficient, Provider has date of correction	11/5/13	2	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	5/14/12	Fire Safety	K	66	Posted "No-smoking" signs in areas where smoking is not permitted or ashtrays provided where smoking was allowed.	D	Deficient, Provider has date of correction	8/4/12	3	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	9/22/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	12/11/14	1	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	8/21/13	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	11/5/13	2	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	5/14/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	F	Deficient, Provider has date of correction	8/4/12	3	Y	N
215084	PATAPSCO VALLEY CENTER	9109 LIBERTY ROAD	RANDALLST OWN	MD	21133	9/22/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	12/11/14	1	Y	N

215258	SPA CREEK CENTER	35 MILKSHAKE LANE	ANNAPOLIS	MD	21403	3/19/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	4/10/14	1	Y	N
215258	SPA CREEK CENTER	35 MILKSHAKE LANE	ANNAPOLIS	MD	21403	3/8/13	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	4/22/13	2	Y	N
215258	SPA CREEK CENTER	35 MILKSHAKE LANE	ANNAPOLIS	MD	21403	1/11/12	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	2/28/12	3	Y	N
Sets: 4	ST JOSEPH'S MINISTRIES	MD														
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	2/3/15	Fire Safety	K	27	Smoke barrier doors that can resist smoke for at least 20 minutes.	D	Deficient, Provider has date of correction	4/29/15	1	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	12/18/13	Fire Safety	K	27	Smoke barrier doors that can resist smoke for at least 20 minutes.	D	Deficient, Provider has date of correction	2/12/14	2	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	10/24/12	Fire Safety	K	27	Smoke barrier doors that can resist smoke for at least 20 minutes.	E	Deficient, Provider has date of correction	11/30/12	3	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	2/3/15	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	4/29/15	1	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	12/18/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	F	Deficient, Provider has date of correction	2/12/14	2	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	10/24/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	11/30/12	3	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	2/3/15	Fire Safety	K	64	Portable fire extinguishers.	B	Deficient, Provider has date of correction	4/29/15	1	Y	N

215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	12/18/13	Fire Safety	K	64	Portable fire extinguishers.	B	Deficient, Provider has date of correction	2/12/14	2	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	10/24/12	Fire Safety	K	64	Portable fire extinguishers.	C	Deficient, Provider has date of correction	11/30/12	3	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	2/3/15	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	4/29/15	1	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	12/18/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	2/12/14	2	Y	N
215267	ST JOSEPH'S MINISTRIES	331 SOUTH SETON AVENUE	EMMITSBURG	MD	21727	10/24/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	11/30/12	3	Y	N
Sets: 1	STELLA MARIS,	MD														
215117	STELLA MARIS, INC.	2300 DULANEY VALLEY RD	TIMONIUM	MD	21093	5/20/14	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	E	Deficient, Provider has date of correction	7/28/14	1	Y	N
215117	STELLA MARIS, INC.	2300 DULANEY VALLEY RD	TIMONIUM	MD	21093	1/28/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	F	Deficient, Provider has date of correction	3/14/13	2	Y	N
215117	STELLA MARIS, INC.	2300 DULANEY VALLEY RD	TIMONIUM	MD	21093	9/28/11	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	B	Deficient, Provider has no plan of correction		3	Y	N
Sets: 1	THE GREEN HOUSE AT	MD														
215356	THE GREEN HOUSE AT STADIUM PLACE	1010 EAST 33RD STREET	BALTIMORE	MD	21218	8/19/14	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	E	Deficient, Provider has date of correction	9/22/14	1	Y	N
215356	THE GREEN HOUSE AT STADIUM PLACE	1010 EAST 33RD STREET	BALTIMORE	MD	21218	10/11/13	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	E	Deficient, Provider has date of correction	12/30/13	2	Y	N

215356	THE GREEN HOUSE AT STADIUM PLACE	1010 EAST 33RD STREET	BALTIMORE	MD	21218	4/12/12	Fire Safety	K	62	Automatic sprinkler systems that have been maintained in working order.	F	Deficient, Provider has date of correction	6/13/12	3	Y	N
Sets: 1	THE PINES GENESIS	MD														
215010	THE PINES GENESIS ELDERCARE	610 DUTCHMAN'S LANE	EASTON	MD	21601	1/29/15	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	D	Deficient, Provider has date of correction	2/27/15	1	Y	N
215010	THE PINES GENESIS ELDERCARE	610 DUTCHMAN'S LANE	EASTON	MD	21601	1/13/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	B	Deficient, Provider has date of correction	1/23/14	2	Y	N
215010	THE PINES GENESIS ELDERCARE	610 DUTCHMAN'S LANE	EASTON	MD	21601	12/14/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	E	Deficient, Provider has date of correction	1/18/13	3	Y	N
Sets: 2	TRANSITIONS HEALTHCARE AT SYKESVILLE	MD														
215136	TRANSITIONS HEALTHCARE AT SYKESVILLE	7309 SECOND AVENUE	SYKESVILLE	MD	21784	3/27/15	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	5/8/15	1	Y	N
215136	TRANSITIONS HEALTHCARE AT SYKESVILLE	7309 SECOND AVENUE	SYKESVILLE	MD	21784	2/11/14	Fire Safety	K	130	Other fire safety features required by fire safety codes.	E	Deficient, Provider has date of correction	3/28/14	2	Y	N
215136	TRANSITIONS HEALTHCARE AT SYKESVILLE	7309 SECOND AVENUE	SYKESVILLE	MD	21784	12/21/12	Fire Safety	K	130	Other fire safety features required by fire safety codes.	D	Deficient, Provider has date of correction	3/1/13	3	Y	N
215136	TRANSITIONS HEALTHCARE AT SYKESVILLE	7309 SECOND AVENUE	SYKESVILLE	MD	21784	3/27/15	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	5/8/15	1	Y	N
215136	TRANSITIONS HEALTHCARE AT SYKESVILLE	7309 SECOND AVENUE	SYKESVILLE	MD	21784	2/11/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	3/4/14	2	Y	N

215136	TRANSITIONS HEALTHCARE AT SYKESVILLE	7309 SECOND AVENUE	SYKESVILLE	MD	21784	12/21/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	E	Deficient, Provider has date of correction	3/1/13	3	Y	N
Sets: 1	UNIVERSITY OF MARYLAND SHORE NURSING AND REHAB	MD														
215262	UNIVERSITY OF MARYLAND SHORE NURSING AND REHAB	200 MORGNEC ROAD	CHESTERTO WN	MD	21620	5/15/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	7/20/14	1	Y	N
215262	UNIVERSITY OF MARYLAND SHORE NURSING AND REHAB	200 MORGNEC ROAD	CHESTERTO WN	MD	21620	1/8/14	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	B	Deficient, Provider has date of correction	1/28/14	2	Y	N
215262	UNIVERSITY OF MARYLAND SHORE NURSING AND REHAB	200 MORGNEC ROAD	CHESTERTO WN	MD	21620	5/9/12	Fire Safety	K	56	An approved automatic sprinkler system connected to the fire alarm system.	D	Deficient, Provider has date of correction	5/30/12	3	Y	N
Sets: 4	VINDOBONA NURSING AND REHABILITATIO N CENTER	MD														
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	6/18/14	Fire Safety	K	12	Approved construction type or materials.	C	Deficient, Provider has date of correction	7/24/14	1	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	5/21/13	Fire Safety	K	12	Approved construction type or materials.	C	Deficient, Provider has date of correction	5/29/13	2	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	4/6/12	Fire Safety	K	12	Approved construction type or materials.	C	Deficient, Provider has date of correction	5/18/12	3	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	6/18/14	Fire Safety	K	15	Fire resistant room wall surfaces.	C	Deficient, Provider has date of correction	7/24/14	1	Y	N

215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	5/21/13	Fire Safety	K	15	Fire resistant room wall surfaces.	E	Deficient, Provider has date of correction	5/29/13	2	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	4/6/12	Fire Safety	K	15	Fire resistant room wall surfaces.	C	Deficient, Provider has date of correction	5/18/12	3	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	6/18/14	Fire Safety	K	52	An approved installation, maintenance and testing program for fire alarm systems.	C	Deficient, Provider has date of correction	7/24/14	1	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	5/21/13	Fire Safety	K	52	An approved installation, maintenance and testing program for fire alarm systems.	F	Deficient, Provider has date of correction	5/29/13	2	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	4/6/12	Fire Safety	K	52	An approved installation, maintenance and testing program for fire alarm systems.	F	Deficient, Provider has date of correction	5/18/12	3	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	6/18/14	Fire Safety	K	147	Properly installed electrical wiring and equipment.	D	Deficient, Provider has date of correction	7/24/14	1	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	5/21/13	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	5/29/13	2	Y	N
215199	VINDOBONA NURSING AND REHABILITATION CENTER	6012 JEFFERSON BLVD	BRADDOCK HEIGHTS	MD	21714	4/6/12	Fire Safety	K	147	Properly installed electrical wiring and equipment.	C	Deficient, Provider has date of correction	5/18/12	3	Y	N
Sets: 1	WILSON HEALTH CARE CENTER	MD														
215099	WILSON HEALTH CARE CENTER	301 RUSSELL AVENUE	GAITHERSBURG	MD	20877	5/8/14	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	E	Deficient, Provider has date of correction	7/3/14	1	Y	N

215099	WILSON HEALTH CARE CENTER	301 RUSSELL AVENUE	GAITHERSBURG	MD	20877	5/3/13	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	C	Deficient, Provider has date of correction	7/5/13	2	Y	N
215099	WILSON HEALTH CARE CENTER	301 RUSSELL AVENUE	GAITHERSBURG	MD	20877	4/23/12	Fire Safety	K	29	Special areas constructed so that walls can resist fire for one hour or an approved fire extinguishing system.	C	Deficient, Provider has date of correction	7/10/12	3	Y	N